



COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: SOME MORE FOOD RESTAURANT OPC (PARES RETIRO)
Lovely Francisco / 09957655628

SAMPLE DESCRIPTION: Purified Water

Submitted By: Carmona Water District

Date Received: July 13, 2022

Date of Sampling: July 13, 2022

Time of Sampling: 1:45 PM

Place of Sampling: C1 G17/18 GF Verdant Strp, Gov. Drive, Verdant Square, Mabuhay, Carmona, Cavite

RLA No.: ML 25898

Date Released: July 22, 2022

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results	Standards
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E.Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results	Standards
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	470	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water. Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC.

Certified by:

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703


Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Vidamar
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water (Carmona National High School)

Submitted By: Carmona Water District

Date Received: July 13, 2022

Date of Sampling: July 13, 2022

Time of Sampling: 10:13 am

Place of Sampling: Carmona National High School

Source of Sampling: School Faucet - Water District

CIN: 0443-GV-CMN

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results	Standards
Total Coliform	Multiple Tube Fermentation	0	MPN/100 ml less than 1.1	MPN/100 ml less than 1.1
Thermotolerant Coliform (E.Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results	Standards
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	CFU/ml 10	CFU/ ml less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water.

Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC.

Certified by :

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703


Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Villamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER

DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water (Cavite State University)

Submitted By: Carmona Water District

Date Received: July 13, 2022

Date of Sampling: July 13, 2022

Time of Sampling: 10:32 am

Place of Sampling: Cavite State University

Source of Sampling: University Faucet

CIN: 0443-GV-CMN

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results MPN/100 ml	Standards MPN/100 ml
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E.Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results CFU/ml	Standards CFU/ ml
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	5	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water. Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC.

Certified by :

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703


Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Villamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water (Maduya Elementary School)

Submitted By: Carmona Water District

Date Received: July 13, 2022

Date of Sampling: July 13, 2022

Time of Sampling: 10:55 am

Place of Sampling: Maduya Elementary School

Source of Sampling: School Faucet

CIN: 0443-GV-CMN

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results	Standards
Total Coliform	Multiple Tube Fermentation	0	MPN/100 ml less than 1.1	MPN/100 ml less than 1.1
Thermotolerant Coliform (E.Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results	Standards
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	CFU/ml 47	CFU/ ml less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water. Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC.

Certified by:

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703


Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Villamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER

DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water (Carmona Elementary School)
Submitted By: Carmona Water District
Date Received: July 13, 2022
Date of Sampling: July 13, 2022
Time of Sampling: 9:45 am
Place of Sampling: 10429 San Mateo St., Cabilang Baybay, Carmona, Cavite
Source of Sampling: School Faucet -Water District
CIN: 0443-GV-CMN

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results	Standards
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E.Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results	Standards
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	5	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water. Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC.

Certified by:

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703


Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Villamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER

DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water (PWDAO)
Submitted By: Carmona Water District
Date Received: July 13, 2022
Date of Sampling: July 13, 2022
Time of Sampling: 9:30 am
Place of Sampling: Magallanes St., Brgy., 7, Carmona, Cavite
Source of Sampling: Water District

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results	Standards
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E. Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results	Standards
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	9	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water. Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC

Certified by:

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703

Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Villamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER

DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water
Submitted By: Carmona Water District
Date Received: July 13, 2022
Date of Sampling: July 13, 2022
Time of Sampling: 9:14 am
Place of Sampling: D-Line, Milagrosa Main Elementary School, Carmona, Cavite
Source of Sampling: Water District

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results	Standards
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E. Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results	Standards
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	15	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water. Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC, 2005

Certified by:

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703

Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Vilamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER

DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water (Mabuhay Elementary School)

Submitted By: Carmona Water District

Date Received: July 13, 2022

Date of Sampling: July 13, 2022

Time of Sampling: 9:00 am

Place of Sampling: Mabuhay Elementary School

Source of Sampling: School Faucet

CIN: 0443-GV-CMN

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results	Standards
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E.Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results	Standards
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	16	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water.

Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC.

Certified by:

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703


Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No. 18428

Noted by:

Engr. Al M. Villamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

SAMPLE DESCRIPTION: Raw Water (Lantic Elementary School)

RLA No.: ML 25898

Date Released: July 22, 2022

Submitted By: Carmona Water District

Date Received: July 13, 2022

Date of Sampling: July 13, 2022

Time of Sampling: 8:46 am

Place of Sampling: Lantic Elementary School

Source of Sampling: Canteen Faucet

CIN: 0443-GV-CMN

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results	Standards
Total Coliform	Multiple Tube Fermentation	0	MPN/100 ml less than 1.1	MPN/100 ml less than 1.1
Thermotolerant Coliform (E.Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results	Standards
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	CFU/ml 40	CFU/ml less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water.

Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC.

Certified by:

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703


Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Villamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER

DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water (Milagrosa Elementary School)

Submitted By: Carmona Water District

Date Received: July 13, 2022

Date of Sampling: July 13, 2022

Time of Sampling: 8:34 am

Place of Sampling: Milgrosa, Carmona, Cavite

Source of Sampling: Water District

CIN: 0443-GV-CMN

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results MPN/100 ml	Standards MPN/100 ml
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E.Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results CFU/ml	Standards CFU/ ml
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	37	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water.

Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC.

Certified by :

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703


Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Vilamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER

DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water (Rodrigo Marqueses)
Submitted By: Carmona Water District
Date Received: July 14, 2022
Date of Sampling: July 14, 2022
Time of Sampling: 11:00 am
Place of Sampling: Anulot St. Brgy., Mabuhay, Carmona, Cavite
Source of Sampling: Water District

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results	Standards
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E. Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results	Standards
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	30	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water. Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC

Certified by:

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703

Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Villamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER

DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water (Celia Montoya)
Submitted By: Carmona Water District
Date Received: July 14, 2022
Date of Sampling: July 14, 2022
Time of Sampling: 10:20 am
Place of Sampling: Milagrosa Homes, Carmona, Cavite
Source of Sampling: Water District
CIN: 0443-GV-CMN

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results MPN/100 ml	Standards MPN/100 ml
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E.Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results CFU/ml	Standards CFU/ ml
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	9	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water. Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC.

Certified by:

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703


Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Villamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water (Dante Gonzales)
Submitted By: Carmona Water District
Date Received: July 14, 2022
Date of Sampling: July 14, 2022
Time of Sampling: 9:20 am
Place of Sampling: Abandoned Rd., Bancal, Carmona, Cavite
Source of Sampling: Water District
CIN: 0443-GV-CMN

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results	Standards
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E.Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results	Standards
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	11	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water. Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC.

Certified by :

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703


Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Villamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water (Maximo Ocampo)
Submitted By: Carmona Water District
Date Received: July 14, 2022
Date of Sampling: July 14, 2022
Time of Sampling: 8:12 am
Place of Sampling: Ocampo Compound, Bancal, Carmona, Cavite
Source of Sampling: Water District
CIN: 0443-GV-CMN

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results	Standards
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E.Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results	Standards
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	10	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water. Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC.

Certified by :

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703

Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Villamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water (Erick Levardo)
Submitted By: Carmona Water District
Date Received: July 14, 2022
Date of Sampling: July 14, 2022
Time of Sampling: 8:00 am
Place of Sampling: CWD D-Line Corchouse, Bancal, Carmona, Cavite
Source of Sampling: Water District

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results	Standards
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E. Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results	Standards
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	44	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water. Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC.

Certified by:

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703

Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Villamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT
(Refilling Station)
SAMPLE DESCRIPTION: Purified Drinking Water
Submitted By: Carmona Water District
Date Received: July 13, 2022
Date of Sampling: July 13, 2022
Time of Sampling: 4:20 pm
Place of Sampling: Cityland, Brgy., Mabuhay, Carmona, Cavite
Source of Sampling: Water District
CIN: 0443-GV-CMN

RLA No.: ML 25898
Date Released: July 22, 2022

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results	Standards
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E. Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results	Standards
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	20	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water. Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC

Certified by :

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703


Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Villamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER

DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water (Jiffy Canaro)
Submitted By: Carmona Water District
Date Received: July 13, 2022
Date of Sampling: July 13, 2022
Time of Sampling: 2:47 pm
Place of Sampling: Blk 10 Lt3 Phase 3, Milagrosa, Carmona, Cavite
Source of Sampling: Water District
CIN: 0443-GV-CMN

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results	Standards
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E.Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results	Standards
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	10	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted PASSED the DOH standard for drinking water. Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC.

Certified by :

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703


Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Villamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER

DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water (Bancal Elementary School)

Submitted By: Carmona Water District

Date Received: July 13, 2022

Date of Sampling: July 13, 2022

Time of Sampling: 2:20 pm

Place of Sampling: Bancal Elementary School

Source of Sampling: School Faucet

CIN: 0443-GV-CMN

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results MPN/100 ml	Standards MPN/100 ml
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E.Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results CFU/ml	Standards CFU/ ml
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	6	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted PASSED the DOH standard for drinking water. Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC.

Certified by :

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703


Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Villamor
General Manager
PRC Reg. No. 53000





COSMOLAB LABORATORIES, INC.

"Caring for the Environment through Quality Testing"



MICROBIOLOGICAL TEST RESULTS for DRINKING WATER DOH Water Laboratory Accreditation No. 04A-0006-2022-LW-2

NAME OF CLIENT: CARMONA WATER DISTRICT

RLA No.: ML 25898

Date Released: July 22, 2022

SAMPLE DESCRIPTION: Raw Water (Nelie Villanueva)
Submitted By: Carmona Water District
Date Received: July 13, 2022
Date of Sampling: July 13, 2022
Time of Sampling: 10:00 am
Place of Sampling: #10176 San Pablo St., Cabilang Baybay, Carmona, Cavite
Source of Sampling: Water District
CIN: 0443-GV-CMN

Test Requested	Methodology	No. of Positive Tubes (out of five tubes)	Results	Standards
Total Coliform	Multiple Tube Fermentation	0	less than 1.1	less than 1.1
Thermotolerant Coliform (E.Coli)	Multiple Tube Fermentation	0	less than 1.1	less than 1.1

Test Requested	Description	Methodology	Results	Standards
Heterotrophic Plate Count	Total Microbial Load	Pour Plate Method	4	less than 500

Note: The methodology used for coliform detection is the Multiple Tube Fermentation Technique as required by the Department of Health. The Heterotrophic Plate Count or the Total Microbial Load is being determined using the Pour Plate Method. The HPC is required in determining water potability (PNSDW 2017)

REMARKS:

The results showed that the water sample submitted **PASSED** the DOH standard for drinking water. Results are those obtained at time of examination and relate only to the sample/s tested.

REFERENCES:

Philippine National Standards for Drinking Water, 2017, Department of Health
Standard Methods for the Examination of Drinking Water and Wastewater
23rd Edition, APHA, Washington, DC.

Certified by:

Maricris C. Manito, RMT,MLS (ASCPi)
Laboratory Microbiologist
PRC Reg. No. 69666
WMLA-18-0703

Approved by:

Engr. Carlos B. Castromayor
Operations Manager
PRC Reg. No 18428

Noted by:

Engr. Al M. Vilamor
General Manager
PRC Reg. No. 53000

