

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1 & 3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

**ROSE TAN**  
9, 23 VILLA SORTEO MILAGROSA  
CARMONA, CAVITE

Certificate No.: **23011911ML**

Account ID: **46CAR0223WSP001**

Sample ID: **J1136**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 9:10AM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **CHLORINATED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

### CERTIFICATE OF MICROBIOLOGICAL ANALYSIS


PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS


\*\*\*NOTHING FOLLOWS\*\*\*


Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



  
**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698

  
**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927

\*\*\* THIS REPORT IS ELECTRONICALLY GENERATED ON 10/13/2023 15:51:38 \*\*\*



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

**HELLEN APUNTAR**  
12471 PATINDIG ARAW MILAGROSA  
CARMONA, CAVITE

Certificate No.: **23011912ML**  
Account ID: **46CAR0223WSP001**  
Sample ID: **J1137**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 9:20AM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **CHLORINATED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

### CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*

Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.

  
**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698  
**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

**ALEJANDRO GACUSAN**  
11, 7 P 143 MILAGROSA  
CARMONA, CAVITE

Certificate No.: **23011913ML**  
Account ID: **46CAR0223WSP001**  
Sample ID: **J1138**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 9:30AM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **CHLORINATED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

### CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS


\*\*\*NOTHING FOLLOWS\*\*\*


Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



  
**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698

  
**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

**ERIBERTO HEBRON**  
12622 PH2, MILAGROSA  
CARMONA, CAVITE

Certificate No.: **23011914ML**  
Account ID: **46CAR0223WSP001**  
Sample ID: **J1139**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 9:45AM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **CHLORINATED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

### CERTIFICATE OF MICROBIOLOGICAL ANALYSIS




PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	2	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*

Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.

  
**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698  
**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

**MYRA VALLEJO**  
B14 L14 PH2 MILAGROSA  
CARMONA, CAVITE

Certificate No.: **23011915ML**  
Account ID: **46CAR0223WSP001**  
Sample ID: **J1140**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 10:00AM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **CHLORINATED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

## CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*


Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698



**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
 Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
 Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
 AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

**CONCHITA MACHA**  
 1338 CARILLO ST. LANTIC  
 CARMONA, CAVITE

Certificate No.: **23011916ML**  
 Account ID: **46CAR0223WSP001**  
 Sample ID: **J1141**

Requested by: **CARMONA WATER DISTRICT**  
 Main Source: **C.W.D.**  
 Water Purpose (Use): **DRINKING**  
 Date/Time Collected: **10/11/2023 10:10AM**  
 Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
 Type of Water: **CHLORINATED**  
 Date/Time Received: **10/11/2023 3:46PM**  
 Date/Time Tested: **10/11/2023 4:00PM**

### CERTIFICATE OF MICROBIOLOGICAL ANALYSIS


PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*


Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**


Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
 Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.

  
**CHLOE JOY C. GABAN, RMicro**  
 Senior Microbiologist  
 PAM Reg. No. 15-00250 RM  
 DOH-NRL Cert. No. WMLA-18-0698



  
**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
 Head of Laboratory  
 PRC Reg. No. 0113927





Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
 Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
 Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
 AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

**RODOLFO PAROLINA**  
 B100 CALUMPANG RD. LANTIC  
 CARMONA, CAVITE

Certificate No.: **23011917ML**  
 Account ID: **46CAR0223WSP001**  
 Sample ID: **J1142**

Requested by: **CARMONA WATER DISTRICT**  
 Main Source: **C.W.D.**  
 Water Purpose (Use): **DRINKING**  
 Date/Time Collected: **10/11/2023 10:25AM**  
 Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
 Type of Water: **CHLORINATED**  
 Date/Time Received: **10/11/2023 3:46PM**  
 Date/Time Tested: **10/11/2023 4:00PM**

### CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*


Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
 Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.

**CHLOE JOY C. GABAN, RMicro**  
 Senior Microbiologist  
 PAM Reg. No. 15-00250 RM  
 DOH-NRL Cert. No. WMLA-18-0698



**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
 Head of Laboratory  
 PRC Reg. No. 0113927



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

**MA. CECILIA GALVEZ**  
ALTAREZ VILLAGE, MADUYA  
CARMONA, CAVITE

Certificate No.: **23011918ML**  
Account ID: **46CAR0223WSP001**  
Sample ID: **J1143**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 10:50AM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **CHLORINATED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

## CERTIFICATE OF MICROBIOLOGICAL ANALYSIS




PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*


Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698



**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927

\*\*\* THIS REPORT IS ELECTRONICALLY GENERATED ON 10/13/2023 15:53:32 \*\*\*



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

**JONATHAN TORRES**  
9425 ROSAL ST, MADUYA  
CARMONA, CAVITE

Certificate No.: **23011919ML**  
Account ID: **46CAR0223WSP001**  
Sample ID: **J1144**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 11:05AM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **CHLORINATED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

## CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	13	< 500	PASS


\*\*\*NOTHING FOLLOWS\*\*\*


Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



  
**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698

  
**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927

\*\*\* THIS REPORT IS ELECTRONICALLY GENERATED ON 10/13/2023 15:53:54 \*\*\*



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

**ARMANDO CADIENTE**  
BULANGAN ST. MADUYA  
CARMONA, CAVITE

Certificate No.: **23011920ML**  
Account ID: **46CAR0223WSP001**  
Sample ID: **J1145**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 11:15AM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **CHLORINATED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

### CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*

Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.

  
**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698  
**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927

\*\*\* THIS REPORT IS ELECTRONICALLY GENERATED ON 10/13/2023 15:54:05 \*\*\*



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

**PLACIDA CLARINO**  
833 ROSARIO ST. BRGY. 8  
CARMONA, CAVITE

Certificate No.: **23011921ML**  
Account ID: **46CAR0223WSP001**  
Sample ID: **J1146**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 11:20AM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **CHLORINATED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

## CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*


Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698



**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927

\*\*\* THIS REPORT IS ELECTRONICALLY GENERATED ON 10/13/2023 15:54:19 \*\*\*



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

**RICHARD HERNANDEZ**  
8232 KONSEHALES BRGY. 8  
CARMONA, CAVITE

Certificate No.: **23011922ML**  
Account ID: **46CAR0223WSP001**  
Sample ID: **J1147**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 11:30AM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **CHLORINATED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

## CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	1	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*


Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698



**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
 Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
 Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
 AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

**FRANCO PURIFICACION**

11357 MAPALAD ST. MABUHAY  
 CARMONA, CAVITE

Certificate No.: **23011923ML**

Account ID: **46CAR0223WSP001**

Sample ID: **J1148**

Requested by: **CARMONA WATER DISTRICT**  
 Main Source: **C.W.D.**  
 Water Purpose (Use): **DRINKING**  
 Date/Time Collected: **10/11/2023 11:45AM**  
 Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
 Type of Water: **CHLORINATED**  
 Date/Time Received: **10/11/2023 3:46PM**  
 Date/Time Tested: **10/11/2023 4:00PM**

**CERTIFICATE OF MICROBIOLOGICAL ANALYSIS**

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*


Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
 Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.




**CHLOE JOY C. GABAN, RMicro**  
 Senior Microbiologist  
 PAM Reg. No. 15-00250 RM  
 DOH-NRL Cert. No. WMLA-18-0698

**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
 Head of Laboratory  
 PRC Reg. No. 0113927



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

**CONSTANCIA LANCETA**  
11158 JM LOYOLA ST. MABUHAY  
CARMONA, CAVITE

Certificate No.: **23011924ML**  
Account ID: **46CAR0223WSP001**  
Sample ID: **J1149**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 11:55AM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **CHLORINATED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

**CERTIFICATE OF MICROBIOLOGICAL ANALYSIS**

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*


Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698



**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

**JOSE CAPARAS**  
COREHOUSE BANCAL  
CARMONA, CAVITE

Certificate No.: **23011925ML**  
Account ID: **46CAR0223WSP001**  
Sample ID: **J1150**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 12:40PM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **CHLORINATED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

### CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*

Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.

  
**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698  
**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927

\*\*\* THIS REPORT IS ELECTRONICALLY GENERATED ON 10/13/2023 15:55:01 \*\*\*



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

**RENATO LANTING**  
14177 BANCAL  
CARMONA, CAVITE

Certificate No.: **23011926ML**  
Account ID: **46CAR0223WSP001**  
Sample ID: **J1151**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 12:50PM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **CHLORINATED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

### CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*

Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698



**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

**JONATHAN OCAMPO**  
14257 OCAMPO COMPD. BANCAL  
CARMONA, CAVITE

Certificate No.: **23011927ML**  
Account ID: **46CAR0223WSP001**  
Sample ID: **J1152**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 1:00PM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **CHLORINATED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

### CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*


Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698



**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
 Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
 Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
 AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

**ROWENA ALCANTARA**  
 1406 BANCAL  
 CARMONA, CAVITE

Certificate No.: **23011928ML**  
 Account ID: **46CAR0223WSP001**  
 Sample ID: **J1153**

Requested by: **CARMONA WATER DISTRICT**  
 Main Source: **C.W.D.**  
 Water Purpose (Use): **DRINKING**  
 Date/Time Collected: **10/11/2023 1:10PM**  
 Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
 Type of Water: **CHLORINATED**  
 Date/Time Received: **10/11/2023 3:46PM**  
 Date/Time Tested: **10/11/2023 4:00PM**

### CERTIFICATE OF MICROBIOLOGICAL ANALYSIS


PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*

Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**


Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
 Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.





**CHLOE JOY C. GABAN, RMicro**  
 Senior Microbiologist  
 PAM Reg. No. 15-00250 RM  
 DOH-NRL Cert. No. WMLA-18-0698



**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
 Head of Laboratory  
 PRC Reg. No. 0113927



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

**FREDIE RIEGO**

B22 L47 MONTECARLO BANCAL  
CARMONA, CAVITE

Certificate No.: **23011930ML**Account ID: **46CAR0223WSP001**  
Sample ID: **J1155**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 1:30PM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **CHLORINATED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

**CERTIFICATE OF MICROBIOLOGICAL ANALYSIS**



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

**\*\*\*NOTHING FOLLOWS\*\*\***

Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.

  
**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698  
**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927

\*\*\* THIS REPORT IS ELECTRONICALLY GENERATED ON 10/13/2023 15:55:53 \*\*\*



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"  
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite  
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com  
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

**CARMONA WATER DISTRICT WATER REFILLING STATION**  
BLOCK 8 LOT 8, JOY ST. CITYLAND SUBD., BRGY. MABUHAY  
CARMONA, CAVITE

Certificate No.: **23011931ML**  
Account ID: **46CAR0223WSP001**  
Sample ID: **J1156**

Requested by: **CARMONA WATER DISTRICT**  
Main Source: **C.W.D.**  
Water Purpose (Use): **DRINKING**  
Date/Time Collected: **10/11/2023 2:00PM**  
Collected By: **J. SINOY**

Sampling Point: **FAUCET**  
Type of Water: **PURIFIED**  
Date/Time Received: **10/11/2023 3:46PM**  
Date/Time Tested: **10/11/2023 4:00PM**

### CERTIFICATE OF MICROBIOLOGICAL ANALYSIS




PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

\*\*\*NOTHING FOLLOWS\*\*\*


Remarks: Results of examination are specifically related to samples as received.  
**Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.**  
**Sample analysis was conducted within eight (8) hours as prescribed by the standards.**

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)  
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



**CHLOE JOY C. GABAN, RMicro**  
Senior Microbiologist  
PAM Reg. No. 15-00250 RM  
DOH-NRL Cert. No. WMLA-18-0698



**PAULO ANTONIO E. CLEMENTE, MD, DPSP**  
Head of Laboratory  
PRC Reg. No. 0113927

\*\*\* THIS REPORT IS ELECTRONICALLY GENERATED ON 10/13/2023 15:56:06 \*\*\*