

DATOC FERDINAND / COOK TERESITA
11806 JOY ST. CITYLAND
CARMONA, CAVITE

Certificate No.: **24002395ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07121**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 9:14AM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	4	< 500	PASS

NOTHING FOLLOWS



Remarks: Results of examination are specifically related to samples as received.

Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.


Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

GARCIA, JAYSON R.
BLK 2 LOT 1 VILLA SORTEO MILAGROSA
CARMONA, CAVITE

Certificate No.: **24002396ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07122**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 9:25AM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.


CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698
PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

LAUDIZA, MYRNA
BLK 10 LOT 42 PHASE 3 MILAGROSA
CARMONA, CAVITE

Certificate No.: **24002397ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07123**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 9:40AM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.


CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698
PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

PURIFICACION JOHN VINCENT
BLK 11LOT 17 PHASE MILAGROSA
CARMONA, CAVITE

Certificate No.: **24002398ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07124**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 9:51AM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	6	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.


CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698
PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

LAURICIO HELEN
BLK 2 LOT 24 PHASE 2 MILAGROSA
CARMONA, CAVITE

Certificate No.: **24002399ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07125**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 10:00AM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.


CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698
PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

MACHA ANGELINA
BLK 13 LOT 58 LANTIC
CARMONA, CAVITE

Certificate No.: **24002400ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07126**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 10:16AM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

MAGCALE ROSALIE

13119 CALUMPANG RD. LANTIC
CARMONA, CAVITE

Certificate No.: **24002401ML**Account ID: **46CAR0223WSP001**Sample ID: **B07127**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 10:30AM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	> 500 est.	< 500	FAIL

*****NOTHING FOLLOWS*****

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.


CHLOE JOY C. GABAN, RMicro

Senior Microbiologist

PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698


PAULO ANTONIO E. CLEMENTE, MD, DPSP

Head of Laboratory
PRC Reg. No. 0113927

*** THIS REPORT IS ELECTRONICALLY GENERATED ON 02/09/2024 17:39:56 ***

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

PURIFICACION REMEDIOS

BLK 1 LOT 29 MILAGROSA HOMES
CARMONA, CAVITE

Certificate No.: **24002402ML**Account ID: **46CAR0223WSP001**Sample ID: **B07128**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 10:44AM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

*****NOTHING FOLLOWS*****

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.


CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698
PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

LIBARDO JOSELITO
BRGY. 1
CARMONA, CAVITE

Certificate No.: **24002403ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07129**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 10:54AM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.


CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698
PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

CONRADO DE GUZMAN
279 SAN JOSE
CARMONA, CAVITE

Certificate No.: **24002404ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07130**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 11:00AM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.


CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698
PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

CECILLE MARTILLANO
478 GM LOYOLA ST.
CARMONA, CAVITE

Certificate No.: **24002405ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07131**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 11:05AM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS




PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.


CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698
PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

ESTELITA MEDINA
9124 BULUNGAN ST. MADUYA
CARMONA, CAVITE

Certificate No.: **24002406ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07132**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 11:15AM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS


Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

TORRES JOEL
843 ROSARIO ST. BRGY. 8
CARMONA, CAVITE

Certificate No.: **24002407ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07133**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 11:25AM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

EDGAR BAYSON

10191 SAN RAFAEL CABILANG BAYBAY
CARMONA, CAVITE

Certificate No.: **24002408ML**

Account ID: **46CAR0223WSP001**

Sample ID: **B07134**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 11:42AM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS


Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

Certificate No.: **24002409ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07135**

BERNARDO MEMIJE
10426 SAN MATEO CABILANG BAYBAY
CARMONA, CAVITE

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 11:52AM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS



Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

MARILOU LIBARDO
4TH ST. COREHOUSE
CARMONA, CAVITE

Certificate No.: **24002410ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07136**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 12:51PM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS


PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS


NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Notes: Comma (,) is used in this report to emphasize presentation of decimal separation/s.


CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698


PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

JONATHAN OCAMPO
14287 BANCAL
CARMONA, CAVITE

Certificate No.: **24002411ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07137**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 1:01PM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.


CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698
PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

MAGNOLIA LIBARDO
GOV. DRIVE BANCAL
CARMONA, CAVITE

Certificate No.: **24002412ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07138**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 1:09PM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS


PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	7	< 500	PASS


NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.


CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698


PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

AQUILINO SARMIENTO
1410 ABANDON RD.
CARMONA, CAVITE

Certificate No.: **24002413ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07139**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 1:19PM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS


Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

DOMINGO JUNLE

BLK 3 LOT 10 MITSUBISHI ST. MONTE CARLO
CARMONA, CAVITE

Certificate No.: **24002414ML**Account ID: **46CAR0223WSP001**Sample ID: **B07140**

Requested by: CARMONA WATER DISTRICT
Main Source: C.W.D.
Water Purpose (Use): DRINKING
Date/Time Collected: 2/7/2024 1:30PM
Collected By: H. MEDINA

Sampling Point: FAUCET
Type of Water: CHLORINATED
Date/Time Received: 2/7/2024 4:09PM
Date/Time Tested: 2/7/2024 4:25PM

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

*****NOTHING FOLLOWS*****

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.


CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698
PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

Certificate No.: **24002415ML**
Account ID: **46CAR0223WSP001**
Sample ID: **B07141**

CARMONA WATER DISTRICT WATER REFILLING STATION
BLOCK 8 LOT 8, JOY ST. CITYLAND SUBD., BRGY. MABUHAY
CARMONA, CAVITE

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **2/7/2024 1:55PM**
Collected By: **H. MEDINA**

Sampling Point: **FAUCET**
Type of Water: **PURIFIED**
Date/Time Received: **2/7/2024 4:09PM**
Date/Time Tested: **2/7/2024 4:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS



PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS



Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927