

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

WILLIAM DE LUNA

**BLOCK 16 LOT 10 SUGAR RD. CITYLAND, MABUHAY
CARMONA, CAVITE**

Certificate No.:

24010115ML

Account ID:

46CAR0223WSP001

Sample ID:

F0492

Requested by:

CARMONA WATER DISTRICT

Main Source:

C.W.D.

Water Purpose (Use):

DRINKING

Date/Time Collected:

6/4/2024 9:05AM

Collected By:

J. SINOY

Sampling Point:

FAUCET

Type of Water:

CHLORINATED

Date/Time Received:

6/4/2024 3:15PM

Date/Time Tested:

6/4/2024 3:25PM

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1.0	≤ 500	PASS

NOTHING FOLLOWS

Remarks:


Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s:

Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association; American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s:

Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro

Senior Microbiologist

PAM Reg. No. 15-00250-RM

DOH-NRL Cert. No. WMLA-18-0698



PAULO ANTONIO E. CLEMENTE, MD, DPSP

Head of Laboratory

PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3, Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

JOSIE LUMBANING

BLOCK 4 LOT 29 VILLA SORTEO, MILAGROSA
CARMONA, CAVITE

Requested by:

Main Source:

Water Purpose (Use):

Date/Time Collected:

Collected By:

CARMONA WATER DISTRICT

C.W.D.

DRINKING

6/4/2024 9:15AM

J. SINOY

Certificate No.:

24010116ML

Account ID:

46CAR0223WSP001

Sample ID:

F0493

Sampling Point:

FAUCET

Type of Water:

CHLORINATED

Date/Time Received:

6/4/2024 3:15PM

Date/Time Tested:

6/4/2024 3:25PM

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS

Remarks:

Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s:

Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEVWW), American Public Health Association; American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s:

Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro

Senior Microbiologist

PAM Reg. No. 15-00250-RM

DOH-NRL Cert. No. WMLA-18-0698



PAULO ANTONIO E. CLEMENTE, MD, DPSP

Head of Laboratory

PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

PH3 ELEMENTARY SCHOOL
MILAGROSA
CARMONA, CAVITE

Certificate No.: **24010117ML**
Account ID:
Sample ID: **46CAR0223WSP001 F0494**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **6/4/2024 9:25AM**
Collected By: **J. SINOY**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **6/4/2024 3:15PM**
Date/Time Tested: **6/4/2024 3:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1.0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Notes: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Certificate No.: **24010118ML**
Account ID: **46CAR0223WSP001**
Sample ID: **F0495**

SHERYL TRINIDAD
BLOCK 8 LOT 18 PHASE 2, MILAGROSA
CARMONA, CAVITE

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **6/4/2024 9:35AM**
Collected By: **J. SINOY**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **6/4/2024 3:15PM**
Date/Time Tested: **6/4/2024 3:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS


PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1.0	≤ 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698

PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

DORENE ARIOLA
BRGY. LANTEC
CARMONA, CAVITE

Certificate No.: **24010119ML**
Account ID: **46CAR0223WSP001**
Sample ID: **F0496**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **6/4/2024 9:45AM**
Collected By: **J. SINOY**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **6/4/2024 3:15PM**
Date/Time Tested: **6/4/2024 3:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	≤ 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B, Pour Plate Method	1	≤ 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association; American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample
Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250-RM
DOH-NRL Cert. No. WMLA-18-0698

PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services, Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

RENALDO LIBRODO
BLOCK 1 PHASE 1, MILAGROSA
CARMONA, CAVITE

Requested by: CARMONA WATER DISTRICT
Main Source: C.W.D.
Water Purpose (Use): DRINKING
Date/Time Collected: 6/4/2024 9:55AM
Collected By: J. SINOY

Certificate No.: 24010120ML
Account ID: 46CAR0223WSP001
Sample ID: F0497

Sampling Point: FAUCET
Type of Water: CHLORINATED
Date/Time Received: 6/4/2024 3:15PM
Date/Time Tested: 6/4/2024 3:25PM

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1.0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.


Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample
Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.




CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698


PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927





Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

CELIA MONTOYA
MILAGROSA HOMES
CARMONA, CAVITE

Requested by: CARMONA WATER DISTRICT
Main Source: C.W.D.
Water Purpose (Use): DRINKING
Date/Time Collected: 6/4/2024 10:05AM
Collected By: J. SINOY

Certificate No.: 24010121ML
Account ID: 46CAR0223WSP001
Sample ID: F0498

Sampling Point: FAUCET
Type of Water: CHLORINATED
Date/Time Received: 6/4/2024 3:15PM
Date/Time Tested: 6/4/2024 3:25PM

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1.0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample
Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698

PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

THIS REPORT IS ELECTRONICALLY GENERATED ON 06/06/2024 18:21:34

Aqualab Analytical Services, Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

JOSELITO LIBRADO
1186 SAN PABLO ST., BRGY. 1
CARMONA, CAVITE

Requested by: CARMONA WATER DISTRICT
Main Source: C.W.D.
Water Purpose (Use): DRINKING
Date/Time Collected: 6/4/2024 10:15AM
Collected By: J. SINOY

Certificate No.: 24010122ML
Account ID: 46CAR0223WSP001
Sample ID: F0499

Sampling Point: FAUCET
Type of Water: CHLORINATED
Date/Time Received: 6/4/2024 3:15PM
Date/Time Tested: 6/4/2024 3:25PM

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1.0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample
Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.




CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698


PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927



AQUALABPH
Integrity in Every Result.

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH



Accredited Laboratory for Water Analysis
Accreditation No. 4A-002-1921-LW-2

CONRADO DE GUZMAN
279 SAN JOSE, BRGY. 2
CARMONA, CAVITE

Certificate No.: **24010123ML**
Account ID: **46CAR0223WSP001**
Sample ID: **F04100**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **6/4/2024 10:25AM**
Collected By: **J. SINOY**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **6/4/2024 3:15PM**
Date/Time Tested: **6/4/2024 3:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1.0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample
Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250.RM
DOH-NRL Cert. No. WMLA-18-0698

PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

THIS REPORT IS ELECTRONICALLY GENERATED ON 06/06/2024 18:21:32

Aqualab Analytical Services, Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

CECILIA MARTILLANO
478 M. LOYOLA, BRGY. 4
CARMONA, CAVITE

Requested by: CARMONA WATER DISTRICT
Main Source: C.W.D.
Water Purpose (Use): DRINKING
Date/Time Collected: 6/4/2024 10:35AM
Collected By: J. SINOY

Certificate No.: 24010124ML
Account ID: 46CAR0223WSP001
Sample ID: F04101

Sampling Point: FAUCET
Type of Water: CHLORINATED
Date/Time Received: 6/4/2024 3:15PM
Date/Time Tested: 6/4/2024 3:25PM

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1.0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250.RM
DOH-NRL Cert. No. WMLA-18-0698

PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT is a registered trademark of AQUALAB PH

LORENA BAYSON
1072 SAN PABLO, CABILANG BAYBAY
CARMONA, CAVITE

Certificate No.: **24010125ML**
Account ID:
Sample ID: **46CAR0223WSP001
F04102**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **6/4/2024 10:45AM**
Collected By: **J. SINOY**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **6/4/2024 3:15PM**
Date/Time Tested: **6/4/2024 3:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1.0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample
Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698

PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT © is a registered trademark of AQUALAB PH

RESTITUTO CONCEPTION
ST. BENEDICT 1
CARMONA, CAVITE

Certificate No.: **24010126ML**
Account ID: **46CAR0223WSP001**
Sample ID: **F04103**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **6/4/2024 10:55AM**
Collected By: **J. SINOY**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **6/4/2024 3:15PM**
Date/Time Tested: **6/4/2024 3:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1.0	< 500	PASS

NOTHING FOLLOWS

Remarks:

Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s:

Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s:

Comma (,) is used in this report to emphasize presentation of decimal separation/s.




CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250-RM
DOH-NRL Cert. No. WMLA-18-0698

PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927



AQUALABPH
Integrity in Every Result.

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH



SUSANA PABLO

H. MABUHAY LATEHAN, BRGY. 8
CARMONA, CAVITE

Certificate No.:

24010127ML

Account ID:

46CAR0223WSP001

Sample ID:

F04104

Requested by:

CARMONA WATER DISTRICT

Main Source:

C.W.D.

Water Purpose (Use):

DRINKING

Date/Time Collected:

6/4/2024 11:10AM

Collected By:

J. SINOY

Sampling Point:

FAUCET

Type of Water:

CHLORINATED

Date/Time Received:

6/4/2024 3:15PM

Date/Time Tested:

6/4/2024 3:25PM

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1.0	< 500	PASS

NOTHING FOLLOWS

Remarks:

Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.

Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s:

Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s:

Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro

Senior Microbiologist

PAM Reg. No. 15-00250 RM

DOH-NRL Cert. No. WMLA-18-0698

EXTERNAL COPY

PAULO ANTONIO E. CLEMENTE, MD, DPSP

Head of Laboratory

PRC Reg. No. 0113927

THIS REPORT IS ELECTRONICALLY GENERATED ON 06/06/2024 18:22:40

LORETA REYES

8178 ROSARIO ST., BRGY. 8
CARMONA, CAVITE

Certificate No.:

24010128ML

Account ID:

46CAR0223WSP001

Sample ID:

F04105

Requested by:

CARMONA WATER DISTRICT

Main Source:

C.W.D.

Water Purpose (Use):

DRINKING

Date/Time Collected:

6/4/2024 11:20AM

Collected By:

J. SINOY

Sampling Point:

FAUCET

Type of Water:

CHLORINATED

Date/Time Received:

6/4/2024 3:15PM

Date/Time Tested:

6/4/2024 3:25PM

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1.0	< 500	PASS

NOTHING FOLLOWS

Remarks:

Results of examination are specifically related to samples as received.
Pursuant to **PNSDW 2017**, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s:

Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEVW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s:

Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro

Senior Microbiologist

PAM Reg. No. 15-00250-RM

DOH-NRL Cert. No. WMLA-18-0698



PAULO ANTONIO E. CLEMENTE, MD, DPSP

Head of Laboratory

PRC Reg. No. 0113927

PINAÑO OBALDO
689 MAGALLANES ST., BRGY. 6
CARMONA, CAVITE

Requested by: CARMONA WATER DISTRICT
Main Source: C.W.D.
Water Purpose (Use): DRINKING
Date/Time Collected: 6/4/2024 11:30AM
Collected By: J. SINOY

Certificate No.: 24010129ML
Account ID: 46CAR0223WSP001
Sample ID: F04106

Sampling Point: FAUCET
Type of Water: CHLORINATED
Date/Time Received: 6/4/2024 3:15PM
Date/Time Tested: 6/4/2024 3:25PM

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1.0	≤ 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

References: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698

PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

MELVIN MAULANIN
1436 BRGY. BANCAL
CARMONA, CAVITE

Certificate No.: **24010130ML**
Account ID: **46CAR0223WSP001**
Sample ID: **F04107**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **6/4/2024 12:10PM**
Collected By: **J. SINOY**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **6/4/2024 3:15PM**
Date/Time Tested: **6/4/2024 3:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1.0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



[Signature]

CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698



[Signature]

PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

MAGNOLIA LEBARDO
GOV. DRIVE BANCAL
CARMONA, CAVITE

Certificate No.:

24010131ML

Account ID:

46CAR0223WSP001

Sample ID:

F04108

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **6/4/2024 12:20PM**
Collected By: **J. SINOY**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **6/4/2024 3:15PM**
Date/Time Tested: **6/4/2024 3:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B, Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS

Remarks:

Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s:

Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s:

Comma (,) is used in this report to emphasize presentation of decimal separation/s.



[Signature]
CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250-RM
DOH-NRL Cert. No. WMLA-18-0698



[Signature]
PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

KYLE TRINIDAD
GOVERNOR DRIVE BANCAL
CARMONA, CAVITE

Certificate No.: **24010132ML**
Account ID: **46CAR0223WSP001**
Sample ID: **F04109**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **6/4/2024 12:35PM**
Collected By: **J. SINOY**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **6/4/2024 3:15PM**
Date/Time Tested: **6/4/2024 3:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1.1	< 1.1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1.0	≤ 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.


Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698

PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927



Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

EDELWINA ISALIT
ABANDONED RD. BANCAL
CARMONA, CAVITE

Certificate No.: 24010133ML
Account ID: 46CAR0223WSP001
Sample ID: F04110

Requested by: CARMONA WATER DISTRICT
Main Source: C.W.D.
Water Purpose (Use): DRINKING
Date/Time Collected: 6/4/2024 12:45PM
Collected By: J. SINOY

Sampling Point: FAUCET
Type of Water: CHLORINATED
Date/Time Received: 6/4/2024 3:15PM
Date/Time Tested: 6/4/2024 3:25PM

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS


PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association; American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform - also Fecal Coliform; MPN/100mL - Most Probable Number per 100mL of sample; cfu - Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698

PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

THIS REPORT IS ELECTRONICALLY GENERATED ON 06/06/2024 18:23:53

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 183 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

ELMER BUENAFLO
BLOCK 24 LOT 19 MONTE CARLO BANCAL
CARMONA, CAVITE

Certificate No.: **24010134ML**
Account ID: **46CAR0223WSP001**
Sample ID: **F04111**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **6/4/2024 1:00PM**
Collected By: **J. SINOY**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **6/4/2024 3:15PM**
Date/Time Tested: **6/4/2024 3:25PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

*****NOTHING FOLLOWS*****

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017).
Thermotolerant Coliform - also Fecal Coliform; MPN/100mL - Most Probable Number per 100mL of sample; cfu - Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separations/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698

PAULO ANTONIO E. CLEMENTE, MD, DPsP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

CARMONA WATER DISTRICT WATER REFILLING STATION
BLOCK 8 LOT 8, JOY ST. CITYLAND SUBD., BRGY. MABUHAY
CARMONA, CAVITE

Requested by: CARMONA WATER DISTRICT
Main Source: C.W.D.
Water Purpose (Use): DRINKING
Date/Time Collected: 6/4/2024 11:50AM
Collected By: J. SINOY

Certificate No.: 24010135ML
Account ID: 46CAR0223WSP001
Sample ID: F04112

Sampling Point: FAUCET
Type of Water: PURIFIED
Date/Time Received: 6/4/2024 3:15PM
Date/Time Tested: 6/4/2024 3:25PM

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

PARAMETER	METHOD OF ANALYSIS	RESULT	LIMIT	REMARKS
Total Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Thermotolerant Coliform, MPN/100mL	9221 Multiple Tube Fermentation Technique	< 1,1	< 1,1	PASS
Heterotrophic Plate Count, cfu/mL	9215 B. Pour Plate Method	< 1,0	< 500	PASS

Remarks: **NOTHING FOLLOWS*****
Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu = Colony Forming Unit per 1mL of sample

Notes: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



CHLOE JOY C. GABAN, RMicro
Senior Microbiologist
PAM Reg. No. 15-00250 RM
DOH-NRL Cert. No. WMLA-18-0698

PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927