

JUN BALGOS

BLK 2 LOT 3 PHASE 3 HALF MILAGROSA
CARMONA, CAVITE

Certificate No.: **25004413ML**

Account ID: **46CAR0223WSP001**

Sample ID: **C05136**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 10:04AM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | < 1,0 | < 500 | PASS |
| ***NOTHING FOLLOWS*** | | | | |

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON

Microbiologist

DOH-NRL Cert. No. WMLA-18-0796



PAULO ANTONIO E. CLEMENTE, MD, DPSP

Head of Laboratory

PRC Reg. No. 0113927

TOLENTINO ROSEMARIE G.
BLK 10 PHASE 3 HALF MILAGROSA
CARMONA, CAVITE

Certificate No.: **25004414ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05137**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 10:10AM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | 7 | < 500 | PASS |

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.


Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.


RONNAMARIE R. MONZON

Microbiologist
DOH-NRL Cert. No. WMLA-18-0796




PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

MENDOZA ANGELINA B.
PATINDIG ARAW MILAGROSA
CARMONA, CAVITE

Certificate No.: **25004415ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05138**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 10:15AM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | < 1,0 | < 500 | PASS |

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON

Microbiologist

DOH-NRL Cert. No. WMLA-18-0796



PAULO ANTONIO E. CLEMENTE, MD, DPSP

Head of Laboratory

PRC Reg. No. 0113927

RERNANDINO IMELDA
BLK 10 LOT 7 PHASE 3 MILAGROSA
CARMONA, CAVITE

Certificate No.: **25004416ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05139**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 10:20AM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | 8 | < 500 | PASS |

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

References: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON
Microbiologist

DOH-NRL Cert. No. WMLA-18-0796

PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

LEGASPI PRISCILLA
15, 17 PHASE 3 MILAGROSA
CARMONA, CAVITE

Certificate No.: **25004417ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05140**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 10:27AM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | < 1,0 | < 500 | PASS |

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON
Microbiologist
DOH-NRL Cert. No. WMLA-18-0796

PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

RAYMOND MANUEL
BLK 14 LOT 29 PHASE 2 MILAGROSA
CARMONA, CAVITE

Certificate No.: **25004418ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05141**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 10:36AM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | < 1,0 | < 500 | PASS |

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON
Microbiologist
DOH-NRL Cert. No. WMLA-18-0796



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

RECAN PIRERIA
1392 LANTIC
CARMONA, CAVITE

Certificate No.: **25004420ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05143**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 10:55AM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | < 1,0 | < 500 | PASS |
| ***NOTHING FOLLOWS*** | | | | |


Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON
Microbiologist
DOH-NRL Cert. No. WMLA-18-0796



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

TRINIDAD SABINA
1370 LANTIC
CARMONA, CAVITE

Certificate No.: **25004419ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05142**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 10:47AM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | < 1,0 | < 500 | PASS |

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample


Notes/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON

Microbiologist

DOH-NRL Cert. No. WMLA-18-0796



PAULO ANTONIO E. CLEMENTE, MD, DPSP

Head of Laboratory

PRC Reg. No. 0113927

REBECA CONDE
4 HOUSE BANCAL
CARMONA, CAVITE

Certificate No.: **25004428ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05151**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 1:53PM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | 1 | < 500 | PASS |

NOTHING FOLLOWS


Remarks: Results of examination are specifically related to samples as received.
Pursuant to **PNSDW 2017**, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON
Microbiologist
DOH-NRL Cert. No. WMLA-18-0796



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

OCSILLOS TEDDY
BLK 22 LOT 4 MONTE CARLO BANCAL
CARMONA, CAVITE

Certificate No.: **25004431ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05154**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 2:20PM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | 2 | < 500 | PASS |
| ***NOTHING FOLLOWS*** | | | | |


Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON
Microbiologist
DOH-NRL Cert. No. WMLA-18-0796



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

CLUBHOUSE C/O TITO B. CORONA
MONTE CARLO
CARMONA, CAVITE

Certificate No.: **25004430ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05153**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 2:14PM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | 5 | < 500 | PASS |

NOTHING FOLLOWS


Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON
Microbiologist
DOH-NRL Cert. No. WMLA-18-0796


PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

RESTRIVERA FREDDIE
BANCAL
CARMONA, CAVITE

Certificate No.: **25004429ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05152**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 1:58PM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | < 1,0 | < 500 | PASS |

NOTHING FOLLOWS


Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON
Microbiologist
DOH-NRL Cert. No. WMLA-18-0796



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

MAULANIN MELVIN
14436 MAULANIN COMP. BANCAL
CARMONA, CAVITE

Certificate No.: **25004427ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05150**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 1:42PM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | 6 | < 500 | PASS |

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON

Microbiologist

DOH-NRL Cert. No. WMLA-18-0796



PAULO ANTONIO E. CLEMENTE, MD, DPSP

Head of Laboratory

PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT ® is a registered trademark of AQUALAB PH

DIAZ CELIA
8130 ROSARIO ST. BRGY. 8
CARMONA, CAVITE

Certificate No.: **25004426ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05149**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 11:43AM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | < 1,0 | < 500 | PASS |

NOTHING FOLLOWS


Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON
Microbiologist
DOH-NRL Cert. No. WMLA-18-0796



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927



AQUALABPH
Integrity in Every Result®

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH



Accredited Laboratory for Water Analysis
Accreditation No. 4A-005-2527-LW-2

ARMANDO CADIENTE
BULANGAN MADUYA
CARMONA, CAVITE

Certificate No.: **25004425ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05148**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 11:35AM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | < 1,0 | < 500 | PASS |

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.

RONNAMARIE R. MONZON

Microbiologist

DOH-NRL Cert. No. WMLA-18-0796



PAULO ANTONIO E. CLEMENTE, MD, DPSP

Head of Laboratory

PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

AUSTRIA ANTONIO
9162 BULANGAN MADUYA
CARMONA, CAVITE

Certificate No.: **25004424ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05147**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 11:30AM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | 1 | < 500 | PASS |

NOTHING FOLLOWS


Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON
Microbiologist
DOH-NRL Cert. No. WMLA-18-0796



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

MARIA CECILIA GICO
ROSAL MADUYA
CARMONA, CAVITE

Certificate No.: **25004423ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05146**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 11:20AM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | < 1,0 | < 500 | PASS |

NOTHING FOLLOWS


Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON
Microbiologist
DOH-NRL Cert. No. WMLA-18-0796



PAULO ANTONIO E. CLEMENTE, MD, DPSP
Head of Laboratory
PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

ALTAREZ ROWENA
9228 ALTAREZ VILLAGE MADUYA
CARMONA, CAVITE

Certificate No.: **25004422ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05145**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 11:12AM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | < 1,0 | < 500 | PASS |
| ***NOTHING FOLLOWS*** | | | | |

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON

Microbiologist

DOH-NRL Cert. No. WMLA-18-0796



PAULO ANTONIO E. CLEMENTE, MD, DPSP

Head of Laboratory

PRC Reg. No. 0113927

Aqualab Analytical Services Inc. Operating under the name "AQUALAB PH"
Block 39 Lot 1&3 Green Estate 3 Malagasang I-G Imus City 4103 Cavite
Tel. No.: (046) 686 3704 | Mobile No. 0919 087 4880 | Email: info@aqualabph.com
AQUALABPH INTEGRITY IN EVERY RESULT® is a registered trademark of AQUALAB PH

MARITA R. CASUBUAN
237 ALTAREZ MADUYA
CARMONA, CAVITE

Certificate No.: **25004421ML**
Account ID: **46CAR0223WSP001**
Sample ID: **C05144**

Requested by: **CARMONA WATER DISTRICT**
Main Source: **C.W.D.**
Water Purpose (Use): **DRINKING**
Date/Time Collected: **3/5/2025 11:05AM**
Collected By: **G. TAPANG**

Sampling Point: **FAUCET**
Type of Water: **CHLORINATED**
Date/Time Received: **3/5/2025 3:38PM**
Date/Time Tested: **3/5/2025 3:50PM**

CERTIFICATE OF MICROBIOLOGICAL ANALYSIS

| PARAMETER | METHOD OF ANALYSIS | RESULT | LIMIT | REMARKS |
|------------------------------------|---|--------|-------|---------|
| Total Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Thermotolerant Coliform, MPN/100mL | 9221 Multiple Tube Fermentation Technique | < 1,1 | < 1,1 | PASS |
| Heterotrophic Plate Count, cfu/mL | 9215 B. Pour Plate Method | 4 | < 500 | PASS |

NOTHING FOLLOWS

Remarks: Results of examination are specifically related to samples as received.
Pursuant to PNSDW 2017, sample was collected according to prescribed aseptic technique and was contained and transported in a sterilized container at controlled temperature by Aqualab PH trained personnel.
Sample analysis was conducted within eight (8) hours as prescribed by the standards.

Reference/s: Methods of Analysis are based on the Standard Methods for the Examination of Water and Wastewater (SMEWW), American Public Health Association, American Water Works Association, 22nd Edition (2012); Parameters and Limits are based on Philippine National Standards for Drinking Water (2017)
Thermotolerant Coliform – also Fecal Coliform; MPN/100mL – Most Probable Number per 100mL of sample; cfu – Colony Forming Unit per 1mL of sample

Note/s: Comma (,) is used in this report to emphasize presentation of decimal separation/s.



RONNAMARIE R. MONZON

Microbiologist

DOH-NRL Cert. No. WMLA-18-0796



PAULO ANTONIO E. CLEMENTE, MD, DPSP

Head of Laboratory
PRC Reg. No. 0113927